



TerraFlow® Mill Test Report

Month of Issue: JUNE 2021

Plant: Seattle, Washington
 Product: TerraFlow 75
 Manufactured: MAY 2021
 Mill Test Report Number: TerraFlow75_JUNE 2021

ASTM C 1157 Standard Requirements

CHEMICAL ANALYSIS			PHYSICAL ANALYSIS			
Item	Spec limit	Test Result	Item	Spec limit	Test Result	
Slag, %	---	75	Passing 325 Sieve (%)	---	95.7	
Type II, %	---	25		Autoclave expansion (%)	0.8	-0.06
				Compressive strength (MPa)		
			3 days	5.0 min	13.9	
			7 days	11.0 min	22.3	
			28 days	--	33.8	

We certify that the above described cement, at the time of shipment, meets the chemical and physical requirements of applicable Specifications for Type MH

Seattle Plant
 5400 W. Marginal Way SW, Seattle, WA 98106
 Phone: 206-937-8025

Certified By:

Daniel Waldron - QC Laboratory Supervisor

June 15, 2021