



Certified to  
NSF/ANSI/CAN 61

## Cement Mill Test Report

Month of Issue: OCTOBER 2022

Plant: **Richmond, British Columbia**  
 Product: **Portland Cement Type IL(15) MS**  
 Mill Test Report #: **R-TIL-22-10**  
 Manufactured: **SEPTEMBER 2022**

### ASTM C595 - 21 Standard Requirements

CHEMICAL ANALYSIS			PHYSICAL ANALYSIS		
Item	Spec limit	Test Result	Item	Spec limit	Test Result
Rapid Method, X-Ray (C 114)			Air content of mortar (%) (C 185)	12 max	5.9
SiO2 (%)	---	18.4	Blaine Fineness (m2/kg) (C 204)	---	449
Al2O3 (%)	---	4.4	Passing 325 (%) (C 430)	---	98.9
Fe2O3 (%)	---	3.0	Autoclave expansion (%) (C 151)	[-0.2 - 0.8]	0.05
CaO (%)	---	63.4	Compressive strength (Mpa [PSI]) (C 109)		
MgO (%)	---	0.7			
SO3 (%)	3.0 max*	2.7			
Loss on ignition @ 950 (%)	10.0 max	6.4			
NaEq (Alkali) (%)	---	0.48			
Insoluble residue (%)	---	0.43			
Adjusted Potential Phase Composition***					
C3S (%)	---	50	3 days	13.0 [1890] min	28.7 4150
C2S (%)	---	15	7 days	20.0 [2900] min	35.9 5200
C3A (%)	---	7	28 days (Reflects previous month's data)	25.0 [3620] min	45.6 6610
C4AF (%)	---	9	Time of setting (minutes)		
			Vicat Initial (C 191)	45-420	109
			Mortar Bar Expansion (C 1038)*		
			14 days, % max	0.020 max	0.005
			Cement Density (C186)		3.09
Sulphate Resistance C1012 (Q3/2021)		0.091			

\* May exceed 3.0% SO3 maximum based on our C 1038 results of <0.02% expansion at 14 days.

Cement meets ASTM C 1157 Type MS

We certify that the above described cement, at the time of shipment, meets the chemical and physical requirements of:  
 ASTM C 595-21 & AASHTO M 240-21 STANDARD SPECIFICATIONS FOR TYPE IL(15), TYPE IL(15) MS CEMENT

Cement complies with NSF 61

Western BU - Richmond  
 7611 No 9 Rd Richmond, BC  
 604 244 4300

Questions or enquiries can be directed to Rob Shogren  
 Rob Shogren, PhD  
 Lafarge - Technical Director  
 5400 W Marginal Way SW, Seattle WA  
 P +1 206 923 9953  
 E Rob.Shogren@lafargeholcim.com

Certified By:

Robyn van Zutphen  
 Quality Supervisor  
 10/13/2022