



Cement

NewCem Plus

Analysis by:	Lafarge Concrete Lab
Sample from :	Seattle Blending Facility
Average Analysis:	May 2022
Mill Certificate ID:	6-23 BSCM



Chemical Analysis

Available Alkali as Equiv. Na ₂ O (previous month's result)	0.6	%
Total Alkalies as Equivalent Na ₂ O	2.60	%
CaO Fly Ash *	17	%
SO ₃ Fly Ash *	1.4	%
SO ₃ Slag **	5.3	%
S Ion Slag **	0.8	%


Physical Analysis

Ground Granulated Blast Furnace Slag SAI, 28 Day **	99	%
Class/Type F Fly Ash Pozzolanic Acivity Index, 28 Day *	109	%
LOI Fly Ash *	0.42	%
Autoclave Fly Ash *	0.00	%
Autoclave Slag **	-0.01	%
45 _u Fly Ash*	15.4	%
45 _u Slag**	6.4	%
Density	2.76	Mg/m ³

Cementitious Blend

Class/Type F Fly Ash Blend Percentage	50	%
Ground Granulated Blast Furnace Slag Blend Percentage	50	%

We hereby certify this blended SCM product meets the requirements of ASTM C-1697 SCMb-50S/50F and CSA A-3000 BMb-50F/S.

Certified : 
 Rob Shogren, P.E.
 Technical Engineer
 Lafarge North America

* 5-23F Centralia Class/Type F Fly Ash Cert

** SEA_NEWCEM_June2023 Ground Granulated Blast Furnace Slag Cert