



Cement Mill Test Report

Date of Issue: August 13, 2024

Plant: Exshaw, AB
 Product: Portland Cement Type III
 Mill Test Report Number: ESW_Type III 2024-7
 Manufactured during the month of: July 2024

ASTM C 150-22 and AASHTO M 85-22 Standard Requirements

CHEMICAL ANALYSIS			PHYSICAL ANALYSIS		
Item	Spec limit	Test Result	Item	Spec limit	Test Result
Rapid Method, X-Ray (C114)			Air content of mortar (%) (C185)	12 max	6
SiO ₂ (%)	---	19.3	Blaine Fineness (m ² /kg) (C204)	---	493
Al ₂ O ₃ (%)	---	4.2	Passing 45 μm (%) (C430)	---	99.4
Fe ₂ O ₃ (%)	---	3.3	Compressive strength (MPa, [psi]) (C109)		
CaO (%)	---	61.9	1 day	12.0 [1740] min	20.8 [3023]
MgO (%)	6.0 max	4.6	3 days	24.0 [3480] min	33.2 [4810]
SO ₃ (%) **	3.5 max	3.4	28 days (Previous Month's Result)		48.2 [6985]
Loss on Ignition (%)	3.5 max	2.4	Time of setting (minutes)		
Insoluble Residue (%)	1.5 max	0.3	Vicat Initial (C191)	45 - 375	65
CO ₂ (%)	---	1.8	Mortar Bar Expansion (%) (C1038)	0.020 max	0.005
Limestone (%)	5.0 max	4.2			
CaCO ₃ in Limestone (%)	70 min	96.0			
Inorganic Process Addition (Lafarge Cement Kiln Dust)	5.0 max				
Adjusted Potential Phase Composition (C150)					
C ₃ S (%)	---	55			
C ₂ S (%)	---	14			
C ₃ A (%)	15 max	6			
C ₄ AF (%)	---	10			

ASTM C 150-22 and AASHTO M 85-22 Optional Chemical Requirements:

Na₂Oeq (%) Weekly Averages: Week 1 0.54 Week 2 0.49 Week 3 0.50 Week 4 0.50 Max 0.60

** May exceed 3.0% SO₃ maximum based on C1038 results of <0.020% expansion at 14 days.

We certify that the above described cement, at the time of shipment, meets the chemical and physical requirements of:

ASTM C 150-22 & AASHTO M 85-22 STANDARD SPECIFICATIONS FOR TYPE III CEMENT; and

ASTM C 150-22 & AASHTO M 85-22 OPTIONAL CHEMICAL REQUIREMENTS FOR TYPE III LOW ALKALI CEMENT.

Exceptions: C430 is excluded from the scope of the AASHTO accreditation.

Western Canada BU - Exshaw Plant
 P.O. Box 160, Highway 1A, Exshaw AB, T0L 2C0
 Phone: 403-673-3815

Certified By:


 John W Blair
 Quality Manager



Certified to
NSF/ANSI/CAN 61



AASHTO
ACCREDITED



Cement Mill Test Report

Date of Issue: August 13, 2024

Plant: Exshaw, AB
Product: Portland Cement Type III
Mill Test Report Number: ESW_Type III 2024-7
Manufactured: July 2024

ASTM C 150-22 and AASHTO M 85-22 Standard Requirements

Additional Data

Item	Test Result	
	Limestone	Inorganic Process Addition Lafarge Cement Kiln Dust
Amount (%)	4.2	-
SiO ₂ (%)	2.1	n/a
Al ₂ O ₃ (%)	0.5	n/a
Fe ₂ O ₃ (%)	0.2	n/a
CaO (%)	49.9	n/a
SO ₃ (%)	0.1	n/a
CO ₂ (%)	42.3	n/a

Base Cement Phase Composition

Item	Test Result
C ₃ S (%)	57
C ₂ S (%)	15
C ₃ A (%)	6
C ₄ AF (%)	10

Specific Gravity (For Information Purposes Only) 3.17

We certify that the data above reflects the materials used in cement manufacture during the production period indicated.

Western Canada BU - Exshaw Plant
P.O. Box 160, Highway 1A, Exshaw AB, T0L 2C0
Phone: 403-673-3815

Certified By:


John W Blair
Quality Manager