



**Cement**

**NewCem Plus**



Certified to  
NSF/ANSI/CAN 61

Analysis by: Lafarge Concrete Lab  
Sample from : Seattle Blending Facility  
Average Analysis: August 2024  
Mill Certificate ID: 9-24 BSCM

**Chemical Analysis**

Available Alkali as Equiv. Na <sub>2</sub> O (previous month's result)	0.3	%
Total Alkalies as Equivalent Na <sub>2</sub> O	2.46	%
CaO Fly Ash *	14	%
SO <sub>3</sub> Fly Ash *	1.1	%
SO <sub>3</sub> Slag **	5	%
S Ion Slag **	0.8	%


**Physical Analysis**

Ground Granulated Blast Furnace Slag SAI, 28 Day **	97	%
Class/Type F Fly Ash Pozzolanic Acivity Index, 28 Day *	91	%
LOI Fly Ash *	0.30	%
45 <sub>u</sub> Fly Ash*	13.0	%
45 <sub>u</sub> Slag**	4.4	%
Density	2.76	Mg/m <sup>3</sup>

**Cementitious Blend**

Class/Type F Fly Ash Blend Percentage	50	%
Ground Granulated Blast Furnace Slag Blend Percentage	50	%

We hereby certify this blended SCM product meets the requirements of ASTM C-1697 SCMb-50S/50F and CSA A-3000 BMb-50F/S.

Certified :   
Rob Shogren, P.E.  
Technical Engineer  
Lafarge North America

\* 9-24F Centralia Class/Type F Fly Ash Cert

\*\* SEA\_NEWCEM\_September2024 Ground Granulated Blast Furnace Slag Cert